



| MECHANICAL NOTES |  |
|------------------|--|
| 1                | NEW LOCATION OF EXISTING ROOF TOP UNIT. CONNECT DUCTWORK FULL SIZE IN THIS VICINITY. EXISTING CONDENSATE PIPING IN THIS VICINITY TO REMAIN. CONNECT NEW CONDENSATE PIPING FULL SIZE IN THIS VICINITY. COORDINATE NEW PIPING AND DUCTWORK WITH LATEST STRUCTURAL SET. REFER TO DETAIL #4 ON SHEET M301 FOR ROOF CURB DETAIL.  |
| 2                | NEW LOCATION OF EXISTING ROOF FAN. EXTEND AND CONNECT EXISTING DUCTWORK FULL SIZE IN THIS VICINITY.  |
| 3                | NEW LOCATION OF EXISTING CHILLED WATER AIR HANDLING UNIT. CONNECT DUCTWORK FULL SIZE IN THIS VICINITY. EXISTING CONDENSATE PIPING IN THIS VICINITY TO REMAIN. CONNECT NEW CONDENSATE PIPING FULL SIZE IN THIS VICINITY. RECONNECT UNIT TO EXISTING CONTROLS SYSTEM AND RESTORE SEQUENCE OF OPERATION FOR THIS UNIT. COORDINATE NEW PIPING AND DUCTWORK WITH LATEST STRUCTURAL SET. |
| 4                | EXTEND AND CONNECT CHILLED WATER PIPING TO EXISTING 3" PIPES IN THIS VICINITY. CONTRACTOR TO CONFIRM EXACT SIZING OF EXISTING PIPES PRIOR TO CONSTRUCTION. PIPES TO CONNECT TO EXISTING RELOCATED ROOFTOP UNIT AS REQUIRED.  |
| 5                | NEW LOCATION OF EXISTING ROOF INTAKE GRAVITY VENTILATOR. EXTEND AND CONNECT EXISTING DUCTWORK FULL SIZE IN THIS VICINITY.  |

1304 Bertrand Dr. Suite F7, Lafayette, LA 70506  
13201 Northwest Fwy. Ste 633, Houston, TX 77040  
(504) 284-7474

Mechanical Contact: Gabrielle Wehner  
Email: gabrielle@meconsulting.com  
General Contact: Terry Kitch  
Email: Terry@meconsulting.com

PROJECT NO. 25051.00

MECHANICAL ROOF PLAN - NEW

DATE: SEPTEMBER 2025

JOB NUMBER: 2025-02

M202

OF 1



IMPROVEMENTS TO  
J.I. BARRON ELEMENTARY SCHOOL  
PINEVILLE, LA  
RPSB# 52-26-01

Owner : Rapides Parish School Board

YEAGER, WATSON & ASSOCIATES, LLC  
ARCHITECTS

118 SOUTH TRENTON STREET  
HOUSTON, LOUISIANA 71270

TELEPHONE: (510) 202-5708  
FACSIMILE: (510) 202-5722