## ELECTRICAL KEYED NOTES:

1. ALL RECEPTACLES LOCATED IN "APARATUS - 130" SHALL BE MOUNTED 36" AFF.
2. ALL RECEPTACLES LOCATED IN "DORM ROOMS" SHALL BE AFCI RATED.
3. ALL EXPOSED CONDUIT WITHIN "APPARATUS BAYS" LOCATED 10' AFF & BELOW SHALL BE RGS.

## ELECTRICAL KEYED NOTES:

1. LOCATE AS REQUIRED FOR MOTORIZED DOOR.
2. LOCATE AS REQUIRED FOR MOTORIZED DOOR CONTROLS. COORDINATE EXACT LOCATION WITH OWNER PRIOR TO ROUGH-IN.
3. APPROXIMATE LOCATION OF WALL-MOUNTED JUNCTION BOX FOR TV CONTROL. CONTRACTOR SHALL ROUTE (1)1"C. AND HDMI CABLE FROM TV IN ASSOCIATED ROOM, ABOVE CEILING AND TO JUNCTION BOX.
4. LOCATE AS REQUIRED FOR RADIO CHARGING STATION. COORDINATE EXACT LOCATION WITH OWNER PRIOR TO ROUGH-IN.
5. DATA RACK PROVIDED BY OTHERS
6. LOCATE AS REQUIRED FOR MOTORIZED LOUVERS. INTERCONNECT WITH EF7 & EF-8 FOR CONTROL.

**1** ELECTRICAL POWER PLAN - MAIN BUILDING
3/16" = 1'-0"




**2** ELECTRICAL POWER PLAN - STORAGE BUILDING
3/16" = 1'-0"


Stantec
Stantec [Formerly Bradley, Blewster & Associates]
1200 Rickyard Lane, Suite 400
Baton Rouge, LA 70802
Tel: 225-765-7400
www.stantec.com


Copyright Reserved
The Contractor shall verify and be responsible for all dimensions. DO NOT scale the drawing - any errors or omissions shall be reported to Stantec without delay. This drawing is the property of Stantec and shall not be reproduced without our written permission and is not to be used in any other way. These drawings are not to be used for any purpose other than that authorized by Stantec is forbidden.


Consultant

| Revision | By | Appd | YYYY.MM.DD |
|---|---|---|---|
| Design Phase Acceptance | | | |

Permit/Seal

STATE OF LOUISIANA
LANDON DAVID BURNS
License No. 46484
PROFESSIONAL ENGINEER
ELECTRICAL ENGINEERING
2025.09.26

Client/Project
CITY OF NATCHITOCHES
NEW FIRE STATION NO. 3
NATCHITOCHES, LOUISIANA

Project No.: 222706059
File Name: 25-035 1B - STANTEC_ARCH_D_VERT
Scale:

| Dwn. | Dsgn. | Chkd. | 2025.09.26 YYYY.MM.DD |
|---|---|---|---|
| | | | |

Title
ELECTRICAL POWER PLAN

Revision: Sheet: of
Drawing No. E300


THOMPSON LUKE & ASSOCIATES, L.L.C.
10705 Rieger Road., STE 101 Baton Rouge, LA 70809
(225)293-9474 | www.tlaeng.com | office@tlaeng.com
TLA PROJECT # 25-035
Frank Saville Thompson - License No. 28854
Landon David Burns - License No. 46484


p:\active projects\25-035 stantec_new fire station no. 3\25-035 ver\25-035 1b - stantec_arch_d_vert