



PLAN NOTES AND LEGEND:

3N ROOF DECK = 3N 18 GAGE GALV. METAL ROOF DECK.

E.O.A. = EDGE OF ANGLE. PROVIDE CONTINUOUS EDGE ANGLE ALONG EDGES WHERE THIS DIMENSION IS INDICATED. SEE DETAIL 1/5501 FOR MORE INFORMATION.

E.O.D. = EDGE OF DECK. EDGE ANGLE IS NOT REQUIRED ALONG EDGES WHERE THIS DIMENSION IS INDICATED.

E.P. = ELEVATOR POSTS. PROVIDE HSS6x6x3/8 POSTS AT GUIDE LOCATIONS ALONG ELEVATOR SHAFT. EXACT NUMBER AND LOCATION OF EACH POST SHALL BE DETERMINED BY GENERAL CONTRACTOR BASED ON LOCATION OF ELEVATOR RAILS. SEE DETAIL 4/5501 FOR POST CONNECTION DETAILS.

(F.P.B) = INDICATES FOLDING PARTITION BEAM PROVIDED FOR SUPPORT OF SUSPENDED FOLDING PARTITION (EITHER WON-DOOR OR ACCORDION STYLE). CONNECTION TO BOTTOM OF BEAM SHALL BE DESIGNED AND PROVIDED BY PARTITION SUPPLIER. GC TO COORDINATE LOCATION AND SIZE OF PUNCHED HOLES IN BOTTOM FLANGE OF BEAM (IF REQUIRED). ALL SURROUNDING FLOOR LOADING AND CEILING LOADING SHALL BE PLACED PRIOR TO PARTITION INSTALLATION. AT LOCATIONS WHERE BEAM IS OFFSET FROM SUPPORTING COLUMNS, FASTEN TO COLUMN WITH ANGLES TOP AND BOTTOM SIM. TO DETAILS 13 & 14 ON 5502.

[A] = INDICATES SPANDREL BEAM WITH GALV. L8x4x7/16 LLH SHELF ANGLE SHOP WELDED TO OUTSIDE FACE OF SPANDREL BEAM ALONG EXTENTS OF BRICK (RE ARCH). SET BOTTOM OF HORIZONTAL LEG AT EL. 17'-8". PROVIDE 2" LONG STITCH WELDS AT ALONG TOP AND BOTTOM AT 12" O.C. EXTEND AND MITER ANGLES AT CORNERS FOR CONTINUOUS SUPPORT OF BRICK VENER.

ALL RECTANGULAR HSS MEMBERS SHALL BE ORIENTED WITH LONG SIDE VERTICAL UNLESS NOTED OTHERWISE.

1 SECOND FLOOR SPANDREL FRAMING PLAN
1/8" = 1'-0"