



**FIRE SPRINKLER NOTE:**

LICENSED SPRINKLER CONTRACTOR TO PROVIDE DRAWINGS AND HYDRAULIC CALCULATIONS FOR AN AUTOMATIC FIRE SPRINKLER SYSTEM FOR THIS BUILDING. TO COMPLY WITH SPACE LAYOUT, NFPA 13, ALL STATE AND LOCAL CODE REQUIREMENTS. REFER TO SPECIFICATIONS FOR ADDITIONAL INFORMATION.

NOTES:

1. THE FOLLOWING IS A LIST OF FIRE HYDRANT FLOW TESTS THAT WERE CONDUCTED BY JEFFERSON SPRINKLER, INC ON 08/24/24 FOR DOWNTOWN HEALTH SERVICES CENTER ALEXANDRIA THE SITE:

A. HYDRANT 1: LOCATION: JACKSON ST @ 9TH ST.  
STATIC @ 63 PSI, RESIDUAL @ 58 PSI, FLOWING GPM @ 1,060.

**1 PLUMBING PLAN - ROOF**  
Scale: 1/8" = 1'-0"

CONSULTANTS

Mendenhall & Associates, LLC  
Civil Engineer  
CABBO Landscape Architecture, LLC  
Landscape Architect  
Fox Nease Engineering, LLC  
Structural Engineer  
Slate O'Brien  
Mechanical Engineer  
Associated Design Group, Inc.  
Electrical Engineer  
Specialty Architecture

ISSUE FOR BID

LOUISIANA STATE UNIVERSITY  
OF ALEXANDRIA  
DOWNTOWN HEALTH SERVICES CENTER  
800 JACKSON ST.  
ALEXANDRIA, LA 71301

PROJECT # 2450-70798 WBS: F-19002488  
ARCH PROJECT # 2023.20 / 1031.00-23  
SITE ID: NEW SITE CODE: 4-40-023  
DATE OCTOBER 10, 2023  
Ashe Broussard Weinzettle Architects, LLP  
Tipton Associates APAC, A Joint Venture  
301 Jackson Street, Suite 205  
Alexandria, LA 71301

NO.	REVISION	DATE

STATE OF LOUISIANA

DOUGLAS CORREY, JR.  
Professional Engineer  
10/10/2025