

1 2ND FLOOR LIGHTING PLAN  
1/8" = 1'-0"



**LIGHTING KEYNOTES:**

- COORDINATE LIGHT FIXTURE LOCATIONS WITH MECHANICAL CONTRACTOR TO AVOID CONFLICTS WITH DUCTWORK AND EQUIPMENT PRIOR TO ROUGH IN.
- CONNECT TO FIXTURE(S) ABOVE/BELOW.
- LOCATION OF (2) SWITCHES FOR MANUAL CONTROL OF LIGHTING IN THE FOLLOWING AREAS:  
1. BUILDING CORRIDORS - WEST WING  
2. BUILDING CORRIDORS - EAST WING
- EGRESS LIGHTING DESIGNATED BY SHADED LIGHT FIXTURES IN THIS AREA SHALL BE CONNECTED TO AN EMERGENCY POWER TRANSFER/BYPASS DEVICE WITH 0-10V DIMMER OVERRIDE FUNCTION, CONNECTED SO THAT NORMAL AND EMERGENCY FIXTURES ARE CONTROLLED TOGETHER BY SINGLE 0-10V DIMMING SWITCH AS DIRECTED, AND UPON LOSS OF NORMAL POWER, EMERGENCY LIGHTS WILL BE ENERGIZED TO FULL BRIGHTNESS. FIXTURE IN ROOM SHOWN SHALL BE CONNECTED TO EMERGENCY LIGHTING CIRCUIT SERVING NEARBY CORRIDOR EGRESS LIGHTING.
- FIXTURES RECESSED UNDER STAIRCASE, CONFIRM LOCATION AND MOUNTING REQUIREMENTS WITH ARCHITECT.

KEYPLAN

