

1 4TH FLOOR LIGHTING PLAN
1/8" = 1'-0"

TRUE PLAN



LIGHTING KEYNOTES:

- COORDINATE LIGHT FIXTURE LOCATIONS WITH MECHANICAL CONTRACTOR TO AVOID CONFLICTS WITH DUCTWORK AND EQUIPMENT PRIOR TO ROUGH IN.
- CONNECT TO FIXTURE(S) BELOW.
- LOCATION OF (2) SWITCHES FOR MANUAL CONTROL OF LIGHTING IN THE FOLLOWING AREAS:
1. BUILDING CORRIDORS - WEST WING
2. BUILDING CORRIDORS - EAST WING
- CONNECT TO BACKLIT SIGN AS DIRECTED BY ARCHITECT.
- FIXTURE TYPE F16 SHOULD BE MOUNTED TO EXTERIOR WALL UNDER WINDOWS AND AIMED TOWARDS ROOF OVERHANG.
- FIXTURE TYPE F16 IN THIS AREA SHOULD BE MOUNTED IN ARCHITECTURAL VALENCE.

NO.	REVISION	DATE

KEYPLAN

