

# New Administrative Office for Verda Elementary School-Re-Bid

Project Number: 25005/CSW

## Addendum No. 2 Items

Issued Thursday, January 22, 2026 at 1:00 P.M. CST

Item	Reference:	Description
001	Addendum Information	This Addendum is issued for the purpose of modifying and/or clarifying the Bidding Documents and shall be construed as being as much a part of the Bidding Documents as though originally contained therein.
002	Addenda Clarifications	Future addenda will be published and sent out no later than 72 hours prior to bid opening. Request for Clarifications may be submitted to the Architect in written form via email to Michele@bhbarch.com.
003	Re: Specifications Section 23 06 20-2.5.J DIFFUSERS, GRILLES AND REGISTERS -	Krueger is an acceptable manufacturer; however, the final products submitted and provided by the Contractor shall strictly meet the requirements of the Project Specifications and Drawings.
004	Re: Specification Section 23 06 20-2.5.K FLEXIBLE AIR DUCTS	Quietflex HPDFlex duct is an acceptable manufacturer; however, the final products submitted and provided by the Contractor shall strictly meet the requirements of the Project Specifications and Drawings.
005	Electrical Prior Approvals	See attached list for Electrical Prior Approvals

END OF ADDENDUM NO. 2

Attachments:

Pre-Bid Sign In Sheet

Electrical Prior Approvals

**Alexandria Office**

301 Jackson Street, Suite 204  
Alexandria, LA 71301  
P: 318.445.8870  
adginc.org | adginc@adginc.org



January 22, 2026

Mr. Jay Lynch  
Barron Heinberg & Brocato Architects and Engineers  
207 Ansley Blvd, Suite D, Second Floor  
Alexandria, LA. 71303

RE: Verda Elementary Administration Building  
Electrical Addendum  
ADG #25247

Dear Jay:

Please include the following electrical addendum items in your next addendum:

**ELECTRICAL ITEMS:**

- 1. Prior Approvals: Subject to compliance with the provisions of the Contract Documents and Specifications, the following manufacturers may be substituted.

<u>MANUFACTURER</u>	<u>PRODUCT</u>
COLOMBIA LIGHTING	Light Fixture Type F1
COLOMBIA LIGHTING	Light Fixture Type F1E
COLOMBIA LIGHTING	Light Fixture Type F2
HE WILLIAMS, INC.	Light Fixture Type F3
HE WILLIAMS, INC.	Light Fixture Type F4
HE WILLIAMS, INC.	Light Fixture Type F5
COMPASS	Light Fixture Type F6
LSI INDUSTRIES	Light Fixture Type F7
WJM POLE	Pole Type F7
LUTRON	Lighting Control OS – Wall Switch
LUTRON	Lighting Control DIMOS – Wall Switch
LUTRON	Lighting Control OS - Ceiling
LUTRON	Lighting Control Power Pack

Contractor shall note that prior approval is by the manufacturer’s name only. Contractor shall ensure that the products used in preparation of his proposal and proposed to be used on this project are equivalent to those specified in appearance, performance, size,

**Member Companies  
Engineering Personnel**

- Herbert “Trey” Alexander, III, P.E.
- Mark A. Aymond, P.E.
- Paulette Benoit
- Lawrence W. Blanchette, P.E.
- John Boulet
- Eric Brignac, P.E.
- Craig Campbell, P.E.
- Rob Campbell, E.I.
- Logan Chaney
- Spencer Comeaux, E.I.
- Joey Cradeur
- Sonya Degetaire
- R.J. Dunn, P.E.
- Artemio Enriquez
- Carl Greene
- Melody Heggins
- Shane Hernandez, P.E.
- Grant Hollier, LC
- Rick LeBlanc
- Roland LeLeux, A.E., HFDP
- Drew Nevers
- James McGough, P.E.
- Connor Martin, E.I.
- Elise Mire, E.I.
- Paul Montgomery
- Mark Neely
- Jennifer Patin, P.E.
- Patrick Pierrotte
- Dale Primeaux
- Andrew Rodriguez
- David B. Stelly, P.E.
- Kyle Suire, E.I.
- Spence Suire
- Ben Tazuin, E.I.
- Eric Thompson
- Ethan Trahan
- Thomas P. VanDeventer
- Matthew Viator, P.E.
- Tucker Wann. E.I.

installation type, and shape. Any material found not to be equivalent to that specified will be rejected. Prior approval of one manufacturer does not automatically approve any subsidiary company, parent company, and/or sister company and their associated products.

If you have any questions, please get in touch with our office.

Thank you,



Carl Greene  
Assistant Electrical Project Manager  
ADG Engineering



**PRE-BID CONFERENCE SIGN IN SHEET**  
 Please Print Clearly and Provide Your Signature for Attendance

No.	Person Name and Company	Signature	E-mail Address	Telephone No
01	Craig Nugent Skip Concrete		nt@skipconcrete.com	318-445-7196
02	Ryan Cump Cenla Contracting		ryan@cenlacontracting.com	318-229-2105
03	Richard Sanders Tudor, Inc.		rsanders@tudorcompanies.com	318-445-3606
04	Karen Sathler SATHLER ELECTRIC		karen@sathlerelectric.com	(318) 880-7544
05	Scott Leary CIS/ADSR		<del>scott@adrs.com</del>	318-308-9347
06	Jay Lynch, AIA, Principal Barron Heinberg & Brocato, LLC		jaylynch@bhbarch.com	
07	Richard Airhart, AIA, Project Manager Barron Heinberg & Brocato, LLC		<a href="mailto:richardairhart@bhbarch.com">richardairhart@bhbarch.com</a>	318-792-2498 or 318-443-7291
08		Signature:		
09		Signature:		
10		Signature:		