



Addendum No. 1

Jefferson Davis Parish Water & Sewer Commission #1

Water System Improvements, Lacassine Water Treatment Plant, Phase 1 – Booster Station

M.A. Project No. A8-23035-DA

February 11, 2026

The following changes, additions, deletions, or alterations to the Contract Documents shall be incorporated into the Contract Documents for the above captioned project:

A. REFERENCE: Project Manual, Advertisement for Bids

Make the following changes:

The deadline for receipt of Bids and Bid opening are hereby rescheduled for Tuesday, February 24, 2026, at 3:00 PM.

B. REFERENCE: Project Manual, Technical Provisions, Section 757 – Service Pump Station, Subsection 757-1.3 Manufacturer’s Qualifications

The following pump station manufacturers are preapproved subject to compliance with Specifications:

Hydromatic

C. REFERENCE: Drawings, Sheet G3.0 – Project Notes

Add the following Piping Note:

11. Drainage pipe within the site shall be HP Storm dual wall pipe, or approved equal.

MEYER & ASSOCIATES, INC.

A handwritten signature in black ink that reads "Mark McCarty". The signature is written in a cursive, slightly slanted style.

Mark McCarty, P.E.