




CENTRALBIDDING
FROM CENTRAL AUCTION HOUSE

**RELOCATION OF WELLSMART HEALTH OF OPELOUSAS RURAL
HEALTH CLINIC**

Opelousas General Health System

Project documents obtained from www.CentralBidding.com

17-Feb-2026 04:13:21 PM



Architects Alliance of Acadiana

(A Professional Architectural Corporation)
Donald J. D'Avy, AIA, President - don@acadarch.com
Mario F. Benoit, AIA, NCARB, Vice President - mario@acadarch.com

February 11, 2026

ADDENDUM NO. THREE (3)

PROJECT: RELOCATION OF WELLSMART HEALTH OF OPELOUSAS RURAL HEALTH CLINIC

ARCHITECT'S PROJECT # A25-08 BIDS DUE 2:00 PM, WEDNESDAY, FEB. 18, 2026

ALL BIDDERS ARE ADVISED OF THE FOLLOWING CHANGES TO THE BID DOCUMENTS.
BIDDERS SHALL ACKNOWLEDGE RECEIPT OF THIS ADDENDUM ON THEIR BID FORM.
This Addendum contains 1 page.

AD3.1 : Clarification regarding scope of flooring and ceiling work required in the Project (in response to RFI from prospective bidder): Refer to issued Drawings and Project Manual as well as Addendum One, Items AD1.5 and AD1.6 for description of flooring work required. Refer to issued Drawings and Project Manual for scope of suspended acoustical ceiling work. Visit the job site prior to bidding to become familiar with existing conditions. The intent is for the existing ceiling tile and grid to remain and be modified as required by new work in the project. Modify the grid system at locations of new partitions and as necessary to accommodate new or relocated mechanical and lighting changes. Where necessary to install new tile or grid components, these shall match the existing in the room or space affected.

AD3.2 : Clarification regarding extent of wall guards and corner guards (in response to RFI from prospective bidder): Two new corner guards as described in Section 10260 are to be installed on the gypsum board rear corners of the new Screen Wall in the Waiting Area. Modifications to the existing wall guards (cutting and new end caps) will be required where new doors and new partitions are shown at Corridor 1 and the Sub-Waiting near the New Unisex Patient Restroom.