



## SECTION 23 34 23 - HVAC POWER VENTILATORS

### PART 1 - GENERAL

#### 1.1 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 01 Specification Sections, apply to this Section.

#### 1.2 SUMMARY

- A. Section Includes:
  - 1. Ceiling-mounted fans.

#### 1.3 ACTION SUBMITTALS

- A. Product Data: For each type of product.
  - 1. Construction details, material descriptions, dimensions of individual components and profiles, and finishes for fans.
  - 2. Rated capacities, operating characteristics, and furnished specialties and accessories.
  - 3. Certified fan performance curves with system operating conditions indicated.
  - 4. Certified fan sound-power ratings.
  - 5. Motor ratings and electrical characteristics, plus motor and electrical accessories.
  - 6. Material thickness and finishes, including color charts.
  - 7. Dampers, including housings, linkages, and operators.
  - 8. Prefabricated roof curbs.
  - 9. Fan speed controllers.
- B. Shop Drawings:
  - 1. Include plans, elevations, sections, and attachment details.
  - 2. Include details of equipment assemblies. Indicate dimensions, weights, loads, required clearances, method of field assembly, components, and location and size of each field connection.
  - 3. Include diagrams for power, signal, and control wiring.

#### 1.4 CLOSEOUT SUBMITTALS

- A. Operation and Maintenance Data: For HVAC power ventilators to include in normal and emergency operation, and maintenance manuals.

### PART 2 - PRODUCTS

#### 2.1 MANUFACTURERS

- A. Subject to compliance with requirements, provide products by one of the following:
  - 1. Loren Cook.
  - 2. GREENHECK.
  - 3. ACME
  - 4. Loren Cook Company.
  - 5. PennBarry.
  - 6. Twin City.

#### 2.2 CEILING-MOUNTED FANS

- A. Housing: Steel, lined with acoustical insulation.
- B. Fan Wheel: Centrifugal wheels directly mounted on motor shaft. Fan shrouds, motor, and fan wheel removable for service.

- C. Back-draft damper: Integral.
- D. Grille: Painted aluminum, louvered grille with flange on intake and thumbscrew or spring retainer attachment to fan housing.
- E. Electrical Requirements: Junction box for electrical connection on housing and receptacle for motor plug-in.
- F. Accessories:
  - 1. Variable-Frequency Motor Controller: Solid-state control to reduce speed from 100 to less than 50 percent.
  - 2. Manual Starter Switch: Single-pole rocker switch assembly with cover and pilot light.
  - 3. Time-Delay Switch: Assembly with single-pole rocker switch, timer, and cover plate.
  - 4. Motion Sensor: Motion detector with adjustable shutoff timer.
  - 5. Ceiling Radiation Damper: Fire-rated assembly with ceramic blanket, stainless steel springs, and fusible link.
  - 6. Filter: Washable aluminum to fit between fan and grille.
  - 7. Isolation: Rubber-in-shear vibration isolators.
  - 8. Manufacturer's standard roof jack or wall cap, and transition fittings.

## 2.3 MOTORS

- A. Comply with NEMA designation, temperature rating, service factor, and efficiency requirements for motors specified in Section 23 05 13 "Common Motor Requirements for HVAC Equipment."
  - 1. Motor Sizes: Minimum size as indicated. If not indicated, large enough so driven load will not require motor to operate in service factor range above 1.0.

## 2.4 SOURCE QUALITY CONTROL

- A. Electrical Components, Devices, and Accessories: Listed and labeled as defined in NFPA 70, by an NRTL, and marked for intended location and application.
- B. AMCA Certification: Fans shall comply with AMCA 11 and bear the AMCA-Certified Ratings Seal.
- C. Fan Sound Ratings: Comply with AMCA 311, and label fans with the AMCA-Certified Ratings Seal. Sound ratings shall comply with AMCA 301. The fans shall be tested according to AMCA 300.
- D. Fan Performance Ratings: Comply with AMCA 211 and label fans with AMCA-Certified Rating Seal. The fans shall be tested for air performance - flow rate, fan pressure, power, fan efficiency, air density, speed of rotation, and fan efficiency - according to AMCA 210/ASHRAE 51.
- E. Operating Limits: Classify according to AMCA 99.
- F. UL Standards: Power ventilators shall comply with UL 705. Power ventilators for use for restaurant kitchen exhaust shall also comply with UL 762.

## PART 3 - EXECUTION

### 3.1 INSTALLATION OF HVAC POWER VENTILATORS

- A. Install power ventilators level and plumb.
- B. Ceiling Units: Suspend units from structure; use steel wire or metal straps.
- C. Install units with clearances for service and maintenance.
- D. Label units with engraved aluminum nameplate. Nameplate shall include the make, model, date of installation, design CFM and static pressure.

### 3.2 DUCTWORK CONNECTIONS

- A. Drawings indicate general arrangement of ducts and duct accessories. Make final duct connections with flexible connectors.

3.3 ELECTRICAL CONNECTIONS

- A. Install electrical devices furnished by manufacturer, but not factory mounted, according to NFPA 70 and NECA 1.

3.4 CONTROL CONNECTIONS

- A. Install control and electrical power wiring to field-mounted control devices.

3.5 ADJUSTING

- A. Adjust damper linkages for proper damper operation.
- B. Comply with requirements in Section 23 05 93 "Testing, Adjusting, and Balancing for HVAC" for testing, adjusting, and balancing procedures.

3.6 DEMONSTRATION

- A. Train Owner's maintenance personnel to adjust, operate, and maintain ventilator fans.

END OF SECTION 23 34 23