

ELECTRICAL SITE PLAN

SCALE: 1" = 20'-0"

ELECTRICAL NOTES: ⬡

1. LOCATION OF EXISTING MECHANICAL ROOM WITH FIRE ALARM PANEL.
2. APPROX. LOCATION OF TWO EXISTING PARKING LOT LIGHTS CURRENTLY SERVED BY A PANEL IN THE OPEN LOT PLAN SOUTH OF THE EXISTING BUILDING (REF. KEY NOTE 5 ON SHEET ED1.01). CONTRACTOR TO INTERCEPT UNDERGROUND CONDUIT/CONDUCTORS SERVING POLE LIGHTS AND EXTEND TO NEW PANEL "LP". REF. PANEL SCHEDULE ON SHEET E5.01. ROUTE CONDUCTORS THROUGH SITE LIGHTING CONTACTOR, REF. DETAIL "B" SHEET E5.01. PROVIDE A 20A BREAKER TO MATCH EXISTING BREAKER SERVING LIGHTS (FIELD VERIFY IF LIGHTS REQUIRE A 1 POLE OR 2 POLE BREAKER).
3. APPROX. LOCATION OF NEW UTILITY RISER POLE. VERIFY EXACT LOCATION WITH ENTERGY.
4. APPROX. LOCATION OF CT METER, CT ENCLOSURE, AND SERVICE DISCONNECT.

TBA STUDIO
ARCHITECTURE
103 Cypress Street
West Monroe, LA 71291
Tel. 318.340.1550
Fax. 318.998.1315
www.tbastudio.com

TBA

SCHOOL OF CONSTRUCTION PRACTICE
LAB BUILDING, UNIVERSITY OF
LOUISIANA MONROE


507 Filhiol Ave, Monroe, LA 71203

DRAWING REVISIONS

No.	Description	Date

DRAWN BY: DWB
CHECKED BY: DWB
SHEET

ES1.01

 11.03.25	CONSULTING ENGINEERS 3003 KNIGHT STREET, SUITE 120 SHREVEPORT, LOUISIANA 71105 phone: 318-425-1482 fax: 318-425-4022 www.AFJMc.com
	ENGINEER: DANIEL W. BROWN, P.E.
	LICENSE NO. 41687
	THESE DRAWINGS DO NOT INCLUDE NECESSARY COMPONENTS FOR CONSTRUCTION SAFETY. 25-033

COPYRIGHT NOTICE:
THIS ENGINEERING DRAWING SHALL BE USED ONLY PURSUANT TO THE AGREEMENT WITH AFJMC. NO OTHER USE, DISSEMINATION OR DUPLICATION MAY BE MADE WITHOUT PRIOR WRITTEN CONSENT OF AFJMC. ALL COMMON LAW RIGHTS OF COPYRIGHT AND OTHERWISE ARE HEREBY SPECIFICALLY RESERVED.

Date: NOV 2025
Project No.: 24-0059
File Name:
DESCRIPTION:
ELECTRICAL SITE PLAN