



Vincent – Shows – Gautreaux, Architects, APALLC
1502 South Huntington Street
Sulphur, Louisiana 70663
Phone: (337) 527-8137
www.vsgarchitects.com

TOTAL PAGES IN THIS ADDENDUM = 2 PAGES

ADDENDUM # 1

Warehouse Renovation RE-BID for Cameron Parish School Board
3151 Trosclair Road
Creole, Louisiana 70632
VSG Project No. 2536

Date Issued: May 27, 2026

NOTE: The following clarifications, changes, additions, or deletions to the Drawings and Specifications shall hereby be incorporated into the Contract Documents for the above referenced project. This addendum supersedes all contrary and conflicting information contained in previous Addenda, Drawings and Specifications and are hereby amended. Prime Bidders shall acknowledge receipt of all Addenda in the space on the Bid Form.

ADDENDUM ITEMS:

1. Bid opening time has been changed to 2:30 p.m. in lieu of the original time of 2:00 p.m. on June 02, 2026. **Bids will be received at the offices of Cameron Parish School Board, 3151 Trosclair Road, Cameron, Louisiana 70631 until 2:30 p.m., Local Time on Tuesday, June 02, 2026.**

Attachments:

Electrical Addenda Items

TOTAL PAGES IN THIS ADDENDUM = 2 PAGES

End of Addendum

D. HICKS CONSULTING

P.O. Box 52311
Lafayette, LA 70505-2311

(337) 233-4688
fax (337) 233-4689
email: jdhicks@dhicksconsulting.com

Warehouse Renovation Re-Bid – Cameron Parish School Board Electrical Addenda Items

1. Prior Approvals:

Prior approvals are based on a limited review of data submitted. Listing in this document does not guarantee final acceptance during the shop drawing review phase of the project. It is the contractor's responsibility to propose equipment that is equivalent to equipment specified.

Lighting Fixtures:

<u>Type</u>	<u>Manufacturer</u>
A2	Metalux, Day-Brite
A3	Metalux, Day-Brite
B4	Metalux, Day-Brite (Note that the lumen output for fixtures noted must be increased to meet the requirement)
B6	Metalux, Day-Brite
C1	Portfolio, Focal Point
D	Eclipse Lighting, Kenall (Requires integral occupancy sensor to dim lighting per IECC 2021)
D2	Eclipse Lighting, Kenall (Requires integral occupancy sensor to dim lighting per IECC 2021)
E	Metalux, Day-Brite
X	Sure-Lites, EnVision LED

Lighting Controls - Wattstopper