

1. STANDING SEAM METAL ROOF SYSTEM AS SPECIFIED. 2. SELF-ADHERING HIGH-TEMP ROOF UNDERLAYMENT AS SPECIFIED. 3. NOT USED. 4. SBS ROOF SYSTEM. COORDINATE ALL MEP EQUIPMENT AND PENETRATIONS. 5. CONCRETE SLAB AS DETAIL. SEE STRUCTURAL DRAWINGS. 6. 24 GA. PREFINISHED GALV. METAL COPING W/ CONT. CLEAT AS SPECIFIED. 7. 24 GA. PREFINISHED GALV. BASE FLASHING PER MANUF. 8. PREFINISHED 24 GA. GALVANIZED EAVE AND RAKE TRIM IN COLORS AS SELECTED. 9. PEMB AS SPECIFIED. SEE STRUCTURAL. PAINT ALL STEEL IN ITS ENTIRETY; SHOP PRIME ALL MEMBERS. 10. EXTERIOR METAL WALL PANELS AS SPECIFIED. VERIFY TYPES, COLORS, AND LOCATIONS AS SPECIFIED AND AS INDICATED ON ELEVATIONS. 11. METAL PANEL ENCLOSURE STRIPS BY PANEL MANUFACTURER IN COLORS TO MATCH ADJACENT PANELS. 12. 1-1/2" RIGID INSULATION AS SPECIFIED. 13. SELF-ADHERING VAPOR BARRIER AS SPECIFIED. 14. 5/8" EXTERIOR GIBB MAT SHEATHING AS SPECIFIED. 15. SEALANT AS SPECIFIED. 16. 18 GA. CFMF TRACKS AS SPECIFIED. SET EXTERIOR AND SHOP WALL TRACKS IN MASTIC BED. 17. 16 GA. CFMF STUDS @ 16" O.C. 18. 16 GA. CFMF BOV HEADER AT ALL OPENINGS; DOUBLE JAMBS. 19. SPRAY FOAM INSULATION W/ INTUMESCENT COATING AS REQUIRED. 20. 5/8" INTERIOR FIRE-RETARDANT PLYWOOD PANELS AS SPECIFIED UP TO 8'-0". PAINT IN COLOR AS SELECTED BY OWNER. 21. DOOR UNIT AS SCHEDULED. 22. STORM-RESISTANT INSULATED WINDOW SYSTEM W/ ANODIZED FINISH TO MATCH FORD STANDARDS. 23. 22 GA. PREFINISHED HAD FLASHING. EXTEND INTO WALL ASSEMBLY. 24. SIMPSON STRONG-TIE HDU HOLD-UP DOWN ANCHORS AT 48" O.C. 25. 2x12 WOOD FRAMING AS SPECIFIED. SEE STRUCTURAL. 26. METAL STRIP AS SPECIFIED. PAINT EXPOSED STEEL. 27. 1-HR FIRE-RATED CMU WALL AS SCHEDULED. 28. COILING DOOR HOOD. SUPPORT PER MANUFACTURER. 29. 5/8" EXT. GYP. BOARD; TAPE, FINISH, PRIME, AND PAINT. INSTALL EXPANSION JOINTS @ 30' O.C. HORIZONTALLY. 30. MINERAL WOOL BATT INSULATION ATTACHMENT SATT INSULATION. 31. PROVIDE FIRESTOP AT ALL RATED ASSEMBLIES AND PENETRATIONS. 32. CONDUCTOR HEAD AND DOWNSPOUT AS SPECIFIED. 33. ROOF SCUPPER AS DETAIL. 34. GUTTERS AND DOWNSPOUTS AS SPECIFIED. PROVIDE SPLASH BACK. 35. GALV. STEEL ROOF ACCESS LADDER AS SPECIFIED. BILCO TYPE E. ROOF FASTEN BASIS OF DESIGN. PROVIDE ALL REQUIRED SUPPORTS, CURBS, FLASHINGS, AND FALL PROTECTION ACCESSORIES PER OSHA REQUIREMENTS. 36. ROOF EDGE ANGLE. SEE STRUCTURAL DRAWINGS. 37. SPLASH BLOCK AS SPECIFIED. 38. 7/8" HAT CHANNEL AT 16" O.C. AS SPECIFIED. 39. SEE FRAMING PLAN FOR ADDITIONAL INFORMATION. 40. STEEL GALV/HANDRAIL SYSTEM. PAINT ALL EXPOSED COMPONENTS. 41. STEEL MEZZANINE DECK AS SPECIFIED. COORDINATE W/ OWNER. 42. MEZZANINE STAIRS AS SPECIFIED. PAINT EXPOSED STEEL. 43. CEILING SYSTEM AS SCHEDULED. REFER TO REFLECTED CEILING PLAN. 44. 1-HR UL V497 ASSEMBLY: (3) LAYERS 5/8" GYP. BD. ON 16GA. 3-5/8" STUDS. 45. BRG. HANG SYSTEM AS SPECIFIED. SEE STRUCTURAL. REMOVE LOGS; PAINT AS SELECTED. 46. COUNTERTOPS AS INDICATED ON DRAWINGS AND INTERIOR ELEVATIONS. 47. OWNER-FURNISHED EQUIPMENT. COORDINATE INSTALLATION. 48. SEE MECHANICAL, ELECTRICAL, AND PLUMBING DRAWINGS. 49. SEE CIVIL DRAWINGS. 50. NOT USED. 51. METAL JOISTS. SEE STRUCTURAL DRAWINGS. 52. 5/8" INTERIOR GYPSUM BOARD; TAPE, FLOAT, PRIME, AND PAINT IN COLOR AS SELECTED. INSTALL EXPANSION JOINTS @ 30' O.C. HORIZONTALLY. 53. TAPERED 4" RIGID INSULATION. SEE ROOF PLAN FOR SLOPES. 54. EAVE STRUT PER BUILDING MANUFACTURER AS SPECIFIED. 55. 1-HR UL 1504 ASSEMBLY: (3) LAYERS 5/8" GYP. BD. ON 16GA. 3-5/8" STUDS. 56. NOT USED. REFER TO KEYNOTE 53. 57. PROVIDE BACKER ROD AND SEALANT AT WINDOW OPENINGS. 58. EXTEND SELF-ADHERING VAPOR BARRIER BELOW WINDOW SILL. 59. PROVIDE WINDOW SILL PAN FLASHING W/ END DAMS. 60. PROVIDE TREATED 2X BLOCKING AT WINDOW HEADS, SILLS, AND JAMBS. 61. EXTEND GYP. BOARD INTO WINDOW JAMBS; PROVIDE CONT. SEALANT. 62. 24 GA. PREFINISHED WINDOW JAMB FLASHING W/ CONT. SEALANT. 63. INDICATES WOOD WINDOW SILL SYSTEM. PAINTED AS SPECIFIED IN COLOR AS SELECTED. 64. PROVIDE TREATED 2X BLOCKING AT PARAPET CAPS; BOLT TO TOP TRACK. 65. COORDINATE DOOR THRESHOLD DEPTH W/ DOOR MANUF. PRIOR TO CONCRETE. 66. INDICATES THE OVERHEAD ACTING COILING DOOR AS SPECIFIED. 67. EXTERIOR ROOF JAMB FLASHING TO EL. 13.95' BELOW FLOOR LINE. 68. NOT USED. 69. INDICATES ROOF STRUCTURE. SEE STRUCTURAL PLANS. 70. INDICATES ROOFING DECKING 22GA. B DECK MIN. OR EQUAL. SEE STRUCTURAL PLANS. 71. NOT USED. REFER TO KEYNOTE 9. 72. EXTEND SELF-ADHERING VAPOR BARRIER OVER PARAPET AND BLOCKING. 73. EXTEND SELF-ADHERING VAPOR BARRIER AS SHOWN 24 GA. THRU-WALL SCUPPER AS DETAIL. COORDINATE FOR WEATHERTIGHT INSTALLATION. 74. INDICATES MISC. TREATED WOOD BLOCKING AS SHOWN. ANCHOR TO STRUCTURE OR FRAMING. 75. 1" RIGID INSULATION AS SPECIFIED. 76. FULLY ADHERED REINFORCING SHEET PER ROOF MANUF. 77. PROVIDE ELASTIC REINFORCING SHEET PER ROOF MANUF. 78. FASTEN PANELS PER REQUIRED WIND LOAD FASTENING PATTERN. 79. NOT USED. REFER TO KEYNOTE 54. 80. EXTEND ROOFING SHEETS AND WEATHERPROOFING BEHIND WALL PANEL AND SECURE TO WALL WITH GALV. METAL TERMINATION BAR. 81. EXTEND ROOFING AND WEATHER BARRIER BEHIND WALL PANEL W/ TERMINAL BAR. 82. PROVIDE 28 GA. R-PANELS AT LOW WALLS NOT VISIBLE FROM GRADE. NOT USED. REFER TO KEYNOTE 8. 83. GUTTER BACK FLASHING TO EXTEND TO ROOF ANCHORAGE. 84. CMU WALLS PER STRUCTURAL. FINISH AND PAINT AS SPECIFIED. 85. SEE STRUCTURAL FOR REQUIRED WIND LOAD ANCHORING PLATES AT BAR JOIST. 86. PROVIDE DOOR THRESHOLD AS SPECIFIED. GROUT UNDER THRESHOLD THAT HANG OVER THE SLAB EDGE. 87. 6"x6" HSS COLUMNS AT NORTH AND SOUTH END WALLS. PROVIDED BY PEMB MANUFACTURER. 88. EQUIPMENT PROVIDED BY OWNER, CONTRACTOR TO COORDINATE REQUIRED BLOCKING FOR MOUNTING. 89. 16GA. 6" CFMF CEILING JOISTS @ 24" O.C. OVER SERVICE WRITERS. 90. METAL WALL "R" PANEL AS SPECIFIED. 91. 2 LAYERS OF 3/4" PLYWOOD WRAPPED WITH 16GA. STAINLESS STEEL TOP AND BOTTOM FINISH. 92. WINDOW TRIM AS SPECIFIED. PAINT IN COLOR TO MATCH THE ADJACENT SIDING. 93. PROVIDE INSULATED CURB AS REQUIRED FOR EQUIPMENT SUPPORT. PROVIDE PREFINISHED METAL FLASHING, COUNTERFLASHING, AND FLASHING ON ENTIRETY. COORDINATE SIZE, HEIGHT, AND INSTALLATION REQUIREMENTS WITH ROOFING AND MECHANICAL EQUIPMENT MANUFACTURER.

