



[illegible]

PANEL SCHEDULE NOTES. (APPLIES TO ALL PANEL SCHEDULES)
1. GFI TYPE BREAKER. 2. TWO PARALLEL SETS OF CONDUIT / CONDUCTORS. 3. THREE PARALLEL SETS OF CONDUIT / CONDUCTORS. 4. FOR FIRE ALARM- PROVIDE RED BREAKER LOCKABLE IN "ON" POSITION. 5. FOR SPD - PROVIDE BREAKER LOCKABLE IN "ON" POSITION.

[illegible]

ASSOCIATED DESIGN GROUP, INC.
3909 West Congress Street, Suite 201
Lafayette, Louisiana 70506
Phone: (337) 234-5710
Email: adginc@adginc.org


Project No. 25326



NEW CONSTRUCTION
FORD PRO
FOR
MIKE WILLIS
2010 PATTON ST.

© COPYRIGHT 2019,
RANDY M. GOODLOE, A.I.A. APAC
ALL INFORMATION, EITHER DRAWN, WRITTEN,
OR IMPLIED APPEARING IN THIS DOCUMENT
SHALL NOT BE DUPLICATED, DISCLOSED, OR
OTHERWISE USED WITHOUT THE WRITTEN
PERMISSION OF THE AUTHOR, RANDY M.
GOODLOE, A.I.A. APAC. THIS DOCUMENT IS AN
INSTRUMENT OF SERVICE AND IS THE SOLE
PROPERTY OF THE AUTHOR. FURTHERMORE,
THE USE OF THIS DOCUMENT FOR ANY
PURPOSE SHALL BE REVOKED, IF THE INTENT
OR DESIGN OF THE CONSTRUCTION
TECHNIQUE OR DETAILS SHOWN HEREIN
ARE NOT ADHERED TO OR THE
CONTRACTUAL AGREEMENT GOVERNING
THEIR USE ARE NOT STRICTLY ADHERED TO.

PROJECT NO.
25012
 PROJECT MANAGER
TM
 DATE ISSUED
2026.05.22
 REVISED



E-602

ELECTRICAL PANEL SCHEDULES
